

February 28, 2024

**MUNICIPALITY OF LAKESHORE
LAKESHORE WATER TREATMENT PLANT AND WATER SERVICE AREA
2023 ANNUAL & SUMMARY REPORT
MADE UNDER O.REG. 170/03**

The Municipality of Lakeshore is required to provide an *Annual Report* for each of its Ministry of the Environment Conservation and Parks (MECP) drinking water systems under Drinking Water Systems Regulation *O.Reg. 170/03* in accordance with the *Safe Drinking Water Act* (as amended). This *Annual Report* is due to be posted for public viewing by the end of February of the following year.

Under *Schedule 22 of Ontario Regulation 170/03*, a regulation made under the *Safe Drinking Water Act 2002*, requires that a large municipal residential drinking-water system must provide to its members of municipal council a Summary Report on various aspects of the system before March 31 of the following year. The Lakeshore Water Service Area is classed as a large municipal residential drinking-water system and is therefore subject to Schedule 22. The purpose of this letter and its attachments is to satisfy this requirement and report on dates from January 1, 2023 until December 31, 2023.

The Municipality of Lakeshore owns and operates four (4) separate drinking water systems under MECP jurisdiction. This letter focusses on the *Lakeshore Water Treatment Plant (WTP) and Water Service Area (WSA)* which is registered as having *Drinking Water System #260091507* under *Municipal Drinking Water License #031-101*. This drinking water system is deemed to be *Large Municipal Residential* having a mathematically assumed population of 31,051 having 11,890 service connections at the end of 2023.

The *John George* WTP, located in Belle River, utilizes a long multibarrier approach to water treatment. This facility has the following process flow: Seasonally chlorinated and screened intake for zebra mussel control, four (4) raw water clarifiers performing coagulation and flocculation with a seasonal taste and odour control option, conventional filtration using Granular Activated Carbon and Sand, Primary Disinfection via UV disinfection, Gaseous Chlorine injection for disinfection both Primary and Secondary. The chemicals utilized at the Belle River WTP are as follows: Poly Aluminum Chloride (DELPAC & STERNPAC Products), Polyelectrolytes, Powdered and Granular Activated Carbon, Chlorine Gas. The WTP does not include Fluoridation in its processes.

The treatment process includes various continuous monitoring equipment for turbidity, chlorine, temperature, pH, UV dose and flows. The WTP's high lift pumps feed the treated water from the *John George* facility to the Belle River Water Tower. The Belle River Water Tower has a maximum operating capacity of 5800 cubic metres and supplies 282 km's of water main under normal operation.

The *John George* WTP is an automated facility that is controlled via a Supervisory Control and Data Acquisition (SCADA) system that has been in place and upgraded since the John George WTP was commissioned in 2009. *O.Reg.170/03* also specifies the data that must be downloaded, stored and at what interval by utilizing the online continuous monitors that allow the plant to be automated and comply with all associated regulations. The results of these online instruments as required in this report are listed below in Table I.

TABLE I
2023 OPERATIONAL TESTING
REGULATION 170/03 DURING 2022

| | Number of Grab Samples | Range of Results (min #)-(max #) | Unit of Measure |
|--|------------------------|----------------------------------|-----------------|
| Turbidity Filter AVG | 8760 | 0.0 – 0.07 | NTU |
| Chlorine | 8760 | 0.77 – 2.28 | Free CL mg/l |
| Distribution Additional Residuals | 829 | 0.22 – 1.72 | Free CL mg/l |

NTU – Nephelometric Turbidity Units
8760 – Indicates continuous monitoring equipment used
CL – Chlorine
mg/l – milligram per litre

Under *Schedule 10* of *O.Reg.170/03* the Municipality of Lakeshore is required to complete microbiological testing of its raw intake water, treated water and distribution water. Treated water is sampled immediately prior to the high lift pumps, any sample taken after the high lift pumps is considered distribution. All of these samples are required to be tested by a certified laboratory accredited for drinking water samples. Table II outlines these analytical results.

TABLE II
2023 MICROBIOLOGICAL TESTING DONE UNDER
SCHEDULE 10 OF REGULATION 170/03

| | NUMBER OF SAMPLES | RANGE OF E.COLI OR FECAL RESULTS (MIN #)-(MAX #) cfu's | RANGE OF TOTAL COLIFORM RESULTS (MIN #)-(MAX #) cfu's | NUMBER OF HPC SAMPLES | RANGE OF HPC RESULTS (MIN #)-(MAX #) cfu's |
|---------------------|-------------------|--|---|-----------------------|--|
| Raw | 52 | 0 – 50 | 0 – 1250 | 0 | NA |
| Treated | 104 | 0 – 0 | 0 – 20 | 104 | <10 – 10 |
| Distribution | 576 | 0 – 27 | 0 – 90 | 314 | <10 - 90 |

cfu – colony forming units
HPC – heterotrophic plate count

The Municipality of Lakeshore is also required to take treated and distribution samples for various organic and inorganic parameters under *O.Reg. 170/03 Schedule 23 & 24*. Table III and Table IV show the treated water sample results from this regulatory sampling

requirement. No organic or inorganic sample exceeded any regulatory requirement as samples for 2023.

TABLE III
2023 INORGANIC PARAMETERS TESTED
TREATED WATER
REGULATION 170/03

| Parameter | Sample Date | Result Value | Unit of Measure | Exceedance |
|-----------|---------------------------------|--------------|-----------------|------------|
| Antimony | October 17 th , 2023 | <0.0001 | mg/l | NO |
| Arsenic | October 17 th , 2023 | 0.0002 | mg/l | NO |
| Barium | October 17 th , 2023 | 0.014 | mg/l | NO |
| Boron | October 17 th , 2023 | 0.009 | mg/l | NO |
| Cadmium | October 17 th , 2023 | <0.000010 | mg/l | NO |
| Chromium | October 17 th , 2023 | <0.002 | mg/l | NO |
| Sodium | October 17 th , 2023 | 9.0 | mg/l | NO |
| Mercury | October 17 th , 2023 | <0.00002 | mg/l | NO |
| Selenium | October 17 th , 2023 | <0.001 | mg/l | NO |
| Uranium | October 17 th , 2023 | <0.00005 | mg/l | NO |
| Fluoride | October 17 th , 2023 | <0.1 | mg/l | NO |
| Nitrite | October 17 th , 2023 | <0.1 | mg/l | NO |
| Nitrate | October 17 th , 2023 | 0.21 | mg/l | NO |

mg/l – milligram per litre

TABLE IV
2023 ORGANIC PARAMETERS
ANNUAL TREATED WATER REQUIREMENT
REGULATION 170/03

| Parameter | Sample Date | Result Value | Unit of Measure | Exceedance |
|---|---------------------------------|--------------|-----------------|------------|
| Alachlor | October 17 th , 2023 | <0.3 | ug/l | NO |
| Atrazine | October 17 th , 2023 | <0.5 | ug/l | NO |
| Atrazine (Desethyl) | October 17 th , 2023 | <0.5 | ug/l | NO |
| Atrazine + N-dealkylated metabolites | October 17 th , 2023 | <0.5 | ug/l | NO |
| Azinphos-methyl | October 17 th , 2023 | <1.0 | ug/l | NO |
| Benzene | October 17 th , 2023 | <0.5 | ug/l | NO |
| Benzo(a)pyrene | October 17 th , 2023 | <0.006 | ug/l | NO |
| Bromoxynil | October 17 th , 2023 | <0.5 | ug/l | NO |
| Carbaryl | October 17 th , 2023 | <3.0 | ug/l | NO |
| Carbofuran | October 17 th , 2023 | <1.0 | ug/l | NO |
| Carbon Tetrachloride | October 17 th , 2023 | <0.2 | ug/l | NO |
| Chlorobenzene | October 17 th , 2023 | <0.5 | ug/l | NO |
| Chlorpyrifos | October 17 th , 2023 | <0.5 | ug/l | NO |
| Diazinon | October 17 th , 2023 | <1.0 | ug/l | NO |
| 1,2-Dichlorobenzene | October 17 th , 2023 | <0.5 | ug/l | NO |
| 1,4-Dichlorobenzene | October 17 th , 2023 | <0.5 | ug/l | NO |
| 1,2-Dichloroethane | October 17 th , 2023 | <0.5 | ug/l | NO |
| 1,1-Dichloroethylene (Methylene chloride) | October 17 th , 2023 | <0.5 | ug/l | NO |
| 2-4 Dichlorophenol | October 17 th , 2023 | <0.2 | ug/l | NO |
| Diclofop-methyl | October 17 th , 2023 | <0.9 | ug/l | NO |
| Dimethoate | October 17 th , 2023 | <1.0 | ug/l | NO |
| Diquat | October 17 th , 2023 | <5.0 | ug/l | NO |
| Diuron | October 17 th , 2023 | <5.0 | ug/l | NO |
| Glyphosate | October 17 th , 2023 | <25 | ug/l | NO |
| Malathion | October 17 th , 2023 | <5.0 | ug/l | NO |
| Metolachlor | October 17 th , 2023 | <3.0 | ug/l | NO |
| Metribuzin | October 17 th , 2023 | <3.0 | ug/l | NO |
| Paraquat | October 17 th , 2023 | <1.0 | ug/l | NO |
| Pentachlorophenol | October 17 th , 2023 | <0.2 | ug/l | NO |
| Phorate | October 17 th , 2023 | <0.3 | ug/l | NO |
| Polychlorinated Biphenyls(PCB) | October 17 th , 2023 | <0.05 | ug/l | NO |
| Prometryne | October 17 th , 2023 | <0.1 | ug/l | NO |
| Simazine | October 17 th , 2023 | <0.5 | ug/l | NO |
| Terbufos | October 17 th , 2023 | <0.5 | ug/l | NO |
| Tetrachloroethylene | October 17 th , 2023 | <0.5 | ug/l | NO |
| 2,3,4,6-Tetrachlorophenol | October 17 th , 2023 | <0.2 | ug/l | NO |
| Triallate | October 17 th , 2023 | <10.0 | ug/l | NO |
| Trichloroethylene | October 17 th , 2023 | <0.5 | ug/l | NO |
| 2,4,6-Trichlorophenol | October 17 th , 2023 | <0.2 | ug/l | NO |
| Trifluralin | October 17 th , 2023 | <0.5 | ug/l | NO |
| Vinyl Chloride | October 17 th , 2023 | <0.2 | ug/l | NO |
| MCPA | October 17 th , 2023 | <10 | ug/l | NO |
| 2,4-(2,4-D) Dichlorophenoxy acetic acid, | October 17 th , 2023 | <1.0 | ug/l | NO |
| Dicamba | October 17 th , 2023 | <1.0 | ug/l | NO |
| Picloram | October 17 th , 2023 | <5.0 | ug/l | NO |

ug/l – microgram per litre

Treated and Distribution water samples are taken for selected organic and inorganic parameters. Trihalomethanes, Haloacetic Acids and Nitrite and Nitrate are sampled quarterly. Lead and alkalinity samples are taken in the distribution system bi-annually. The requirement to take and the amount of samples taken for these parameters falls under O.Reg. 170/03 and is based on population served. Tables V, VI and VII show the results satisfying the regulation.

TABLE V
2023 NITRATE AND NITRITE RESULTS
QUARTERLY TREATED WATER REQUIREMENT
REGULATION 170/03

| Parameter | Date | Result | Unit | Exceedance |
|-----------|-------------------|--------|------|------------|
| Nitrate | February 28, 2023 | 2.28 | mg/L | NO |
| | May 30, 2023 | 1.27 | mg/L | NO |
| | August 15, 2023 | 1.70 | mg/L | NO |
| | November 21, 2023 | 0.57 | mg/L | NO |
| Nitrite | February 28, 2023 | <0.05 | mg/L | NO |
| | May 30, 2023 | <0.05 | mg/L | NO |
| | August 15, 2023 | <0.05 | mg/L | NO |
| | November 21, 2023 | <0.05 | mg/L | NO |
| THM's | February 28, 2023 | 12 | ug/L | NO |
| | May 30, 2023 | 24 | ug/L | NO |
| | August 15, 2023 | 33 | ug/L | NO |
| | November 21, 2023 | 13 | ug/L | NO |
| | RAA | 20.5 | ug/L | NO |

ug/l – microgram per litre
RAA – Running Annual Average

TABLE VI
2023 TRIHALOMETHANES & HALOACETIC ACIDS RESULTS
QUARTERLY DISTRIBUTION WATER REQUIREMENT
REGULATION 170/03

| Parameter | Sample Schedule | Result | Unit of Measure | Exceedance |
|-------------------------|-----------------|--------|-----------------|------------|
| THM (Treated Water RAA) | Quarterly | 20.5 | mg/l | NO |
| THM (Distribution RAA) | Quarterly | 30.5 | mg/l | NO |
| HAA (Distribution RAA) | Quarterly | 8.85 | mg/l | NO |

mg/l – milligram per litre

TABLE VII
2023 LEAD & ALKALINITY RESULTS
DISTRIBUTION WATER
REGULATION 170/03

| Location Type | Number of Samples | Range of Lead Results (min#) – (max #) | Unit of Measure | Number of Exceedances |
|---------------------------|-------------------|--|-----------------|-----------------------|
| Distribution (Lead) | 14 | 0.00014 – 0.00103 | mg/l | NONE |
| Distribution (Alkalinity) | 14 | 85 - 102 | mg/l | NA |

mg/l – milligram per litre

TABLE VIII
2023 RESIDUAL MANAGEMENT
TOTAL SUSPENDED SOLIDS
REQUIRED UNDER MUNICIPAL DRINKING WATER LICENCE

| Date of legal instrument issued | Parameter | Date Sampled | Result | Unit of Measure |
|---------------------------------|------------------------|--------------|--------|-----------------|
| May 21, 2021 MDWL 031-101 #4 | Total Suspended Solids | RAA | 8.1 | mg/l |

RAA – Running Annual Average (monthly sample averaged)

The water treatment system and service area require extensive maintenance annually. These costs are required to install new equipment and maintain the current assets. A brief description of large priced capital items is listed as part of this letter. Below is Table IX which lists the large expenditures for 2023 within the Lakeshore Water Treatment Plant and Water Service Area.

TABLE IX
2022 PROJECT COSTS

| Project | Cost Incurred |
|---|---------------|
| Meter Replacement Program | \$566,536 |
| PLC (Programable Logic Controller) replacements | \$104,914 |
| Belle River WTP Lifecycle Assessment | \$25,440 |
| Belle River High Lift Pump Design | \$4,477 |
| CO2 Metering System | \$6,389 |
| Strong Road Watermain Improvements | \$6,099 |
| West Puce Road Watermain Improvements | \$54,301 |
| Railway Avenue Watermain Improvements | \$16,857 |

Under *O.Reg.170/03* the Municipality is required to report notices submitted in accordance with the *Safe Drinking Water Act*. There were two notices filed and reported to the *Spills Action Centre* and their details can be seen below in Table X.

TABLE X
Detail of ADWQI Notice's filed 2023

| Incident Date | Parameter | Result | Unit of Measure | Corrective Action | Corrective Action Date |
|--------------------------------|----------------------------|---------------------------------------|-----------------|--------------------|--------------------------------|
| July 5 th , 2023 | Microbiological | 1 Total Coliform / Distribution | CFU | Flush and Resample | July 6 th , 2023 |
| July 11 th , 2023 | Microbiological | 27 Total Coliform / Distribution | CFU | Flush and Resample | July 12 th , 2023 |
| August 18 th , 2023 | Chemical / Microbiological | 0.20 ug/L Total Microcystin / Treated | ug/L | Resample x 4 | August 25 th , 2023 |

As shown above there were three occasions when the Lakeshore Water Service Area was not in compliance with the 1 requirement of the Safe Drinking Water Act 2002, associated regulations, system approvals, Drinking Water Works Permit, Municipal Drinking Water Licence and provincial officer orders. In Table XI below the specific legislation requirements and corrective measures are stated.

Table XI
Legislative Requirements & Corrective Actions
ADWQI Notice's Filed

| Drinking Water Legislation | Requirement(s) the System Failed to Meet | Specify the Duration of the Failure (i.e. date(s)) | Describe the Measures Taken to Correct the Failure | Status (complete or outstanding) |
|--|--|---|--|----------------------------------|
| Safe Drinking Water Act | Associated Regulations | See Below | See Below | |
| Ontario Regulations | O.Reg. 169/03 | July 5 th , July 11 th , August 18 th | Flush and Resample | Complete |
| System Approvals | none | | | |
| System Drinking Water Works Permit and Municipal Drinking Water Licence | none | | | |
| Provincial Officer's Order | None | | | |

A summary of the quantities and flow rates of water supplied during the period covered by the report, including monthly average flows, maximum daily flows and daily maximum flow rates taken per minute is required reporting in the Summary Report.

The Lakeshore Water Service Area operated under the following listed Permits to Take Water and did not exceed its limits in 2023.

(PTTW) Number 3648-B3EQWX issued on August 16, 2018 has the following flow conditions:

- Maximum Allowable Amount Taken per Minute (Litres/Min) **34,722**
- Maximum Allowable Amount Taken Per Day (Litres/Day) **30,000,000**

The maximum amounts of raw water taken during 2023 are as follows:

- Maximum Amount Taken per Minute in 2023 (Litres/Min) **17,034 (October 3, 2023)**
- Maximum Amount Taken Per Day in 2023 (Litres/Day) **18,439,840 (June 4, 2023)**

The Lakeshore Water Service Area operated under Drinking Water Works Permit #031-201 and Municipal Drinking Water Licence (MDWL) #031-101 during 2023:

The MDWL has the following flow conditions:

- The maximum daily volume of treated water that flows from the treatment subsystem to the distribution subsystem shall not exceed **36,400 m³/day**.
- The maximum daily volume of water pumped into the distribution system in 2023 was **18,206 m³/day**

The following Table XII & XIII give the monthly average and maximum flows for the Lakeshore Water Service Area.

Table XII
2023 Raw Water Flow Data
Lake Water Used

| Month | Maximum Allowed Flow Rate (m ³ /Day) | Average Flow (m ³ /Day) | Maximum Flow (m ³ /Day) | Maximum Allowed Flow Rate (Litres/Minute) | Maximum Flow Rate (Litres/Minute) |
|-----------|---|------------------------------------|------------------------------------|---|-----------------------------------|
| January | 30,000 | 7,870 | 8,357 | 34,722 | 15,246 |
| February | 30,000 | 8,456 | 15,777 | 34,722 | 14,940 |
| March | 30,000 | 7,903 | 8,342 | 34,722 | 14,340 |
| April | 30,000 | 8,477 | 9,250 | 34,722 | 14,412 |
| May | 30,000 | 11,377 | 17,352 | 34,722 | 16,032 |
| June | 30,000 | 13,817 | 18,439 | 34,722 | 16,782 |
| July | 30,000 | 11,337 | 13,840 | 34,722 | 16,530 |
| August | 30,000 | 10,888 | 13,770 | 34,722 | 16,956 |
| September | 30,000 | 11,020 | 13,399 | 34,722 | 16,884 |
| October | 30,000 | 8,817 | 11,152 | 34,722 | 17,034 |
| November | 30,000 | 7,929 | 8,513 | 34,722 | 8,502 |
| December | 30,000 | 8,047 | 9,485 | 34,722 | 8,826 |

Table XIII
2023 Treated Water Flow Data
Water Sent to Distribution System

| Month | Maximum Allowed Flow Rate (m ³ /Day) | Average Daily Flow (m ³ /Day) | Maximum Daily Flow (m ³ /Day) | Maximum Flow Rate (Litres/Minute) |
|-----------|---|--|--|-----------------------------------|
| January | 36,400 | 7,848 | 8,485 | 11,790 |
| February | 36,400 | 8,410 | 13,050 | 12,195 |
| March | 36,400 | 7,946 | 8,629 | 11,756 |
| April | 36,400 | 8,483 | 9,530 | 11,767 |
| May | 36,400 | 11,275 | 16,079 | 12,442 |
| June | 36,400 | 13,613 | 18,206 | 36,000 |
| July | 36,400 | 11,171 | 13,737 | 15,930 |
| August | 36,400 | 10,766 | 13,119 | 17,685 |
| September | 36,400 | 10,773 | 13,287 | 17,685 |
| October | 36,400 | 8,745 | 10,737 | 11,970 |
| November | 36,400 | 7,980 | 8,678 | 23,220 |
| December | 36,400 | 8,075 | 11,063 | 11,801 |

 - Flow Metre Calibration, not actual effluent max flow

This report is made available to the public for viewing on the Municipality's website at <https://www.lakeshore.ca/en/municipal-services/plans-publications-and-reports.aspx#Drinking-Water-Annual-Reports>. The report is printed and available for viewing at 419 Notre Dame Street (Town Hall) & 492 Lakeview Dr., Belle River, Ontario. Both versions are available after February 29th, 2024.