

**Date:** February 25, 2025  
**From:** Engineering & Infrastructure Division  
**To:** Ian Search, Planner 1  
**Re:** Committee of Adjustment – March 12, 2025 – A/02/2025

---

Operations has reviewed A-02-2025 – 256 Donald Crescent. application and offer the following comments:

- All roof drains/ downspouts should be splash padded and should not tie into storm water management system.

*Vaibhav Desai*

---

Team Leader – Development Engineering and Approvals

Approved by: Krystal Kalbol, P.Eng.