

Date: May 4, 2023

From: Sydnee Rivest, CET, Engineering Technologist - Development

To: Ian Search, Planner 1

Re: Committee of Adjustment – May 17, 2023 – A/15/2023

Operations has reviewed A/15/2023 - 1646 Caille Ave. application and offer the following comments:

Comments
<ul style="list-style-type: none">• Construction of the accessory buildings should not adversely impact the side yard drainage or adjacent neighboring lands.• The proposed washroom in the accessory building cannot be supported at this time. Lakeshore is currently experiencing sanitary conveyance constraints in this area and cannot support further contributions into Lakeshore's sanitary system.

If you have any questions or require further clarification, please do not hesitate to contact the Engineering & Infrastructure Division.

Sydnee Rivest, CET, rcji

Engineering Technologist – Development