

Date: May 3, 2023
From: Sydnee Rivest, CET, Engineering Technologist - Development
To: Ian Search, Planner 1
Re: Committee of Adjustment – May 17, 2023 – B/10/2023

Operations has reviewed B/10/2023 - 334 East Ruscom River Road application and offer the following comments:

Comments
<ul style="list-style-type: none">• A Drainage Apportionment will be required as part of this severance under the Drainage Act.• Surface water and subsurface drainage tiles and water should be redirected around the severed parcel.

If you have any questions or require further clarification, please do not hesitate to contact the Engineering & Infrastructure Division.

Sydnee Rivest, CET, rcji

Engineering Technologist – Development